

December 22, 2009

DESIGN HOMES, INC.
KURT SMITH
600 N MARQUETTE RD
PO BOX 239
PRAIRIE DU CHIEN WI 53821

Re: Description: PREFABRICATED PLUMBING SYSTEM
Manufacturer: DESIGN HOMES, INC.
Product Name: NONE
Model Number(s): PLB 1
Product File No: 20090424

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of June 2015.

This approval is contingent upon compliance with the following stipulation(s):

- The flowing water supply pressure at the point(s) of connection must be at least 20 psig.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- The shower valve must be served by a thermostatic mixing valve or be a pressure balancing valve when this model is installed in a public building.

This approval supersedes the approval issued on June 8, 2005 under product file number 20050304.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20050304.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: jerry.thompson@wi.gov